


BLE to 0-10V Ceiling Mounted AC PIR Sensor With Relay SR-SV9030B-PIR-LBV

Features

- Bluetooth to 0-10V sensor controller
- Bluetooth[®] NLC Certified
- · Mesh network, which has a much longer control distance, transmits received signals to neighboring devices
- All devices on 0-10V line are broadcast controlled by mobile application
- Supporting our kinetic energy switches and EnOcean switches EWSSB and EWSDB
- Autonomos sensor-based control
- · Support sensitivity adjustment, Mesh Network, a better method to deal with false trigger
- · Available with Magnetic reset (touch reset icon for 5 seconds)
- On-board antenna
- · Waterproof grade: IP20, suitable for indoor luminaries
- 5 years warranty





Parameters

Sensing

Installation

Input & Output Characteristics		
Operating voltage	100-277VAC 50/60Hz	
Stand-by power	<0.5W	
Relay	Max.5A @ 120V, 277VAC	

Environment Parameters		
Operation temperature	Ta: -10°C ~ +50°C	
IPrating	IP20	

Safety & EMC	
EMC standard (EMC)	EN55015, EN61000, EN61547
Safety standard (LVD)	EN60669-1, EN60669-2-1 AS/NZS60669-1/-2-1
RED	EN300328, EN301489-1/-17
Certication	ENEC, CE, RED, UL

Max. \$26m @ 12m height

Max.12m

Mechanical Data		
Dimension	See below	
Material	Flame-retardant/ABS	
Protection Class	Class II	

Connectors		
Terminal block/Wire size	AC Line: 18 AWG Signal Line: 22 AWG	
Wire strip length	10mm	

Product info


Movement detection


Reset icon: Please using magnetic to reset the devices (hold for 5 seconds)

Cable Wiring:

L (Input) : Black, 18 AWG ; N (Input) : White, 18 AWG L'(Output) : Red, 18 AWG

Dim+ (Input) : Violet, 22 AWG Dim- (Input) : Pink, 22 AWG





Package info


1x Sensor with Low-bay lens (Default)

- 1x High-bay lens (Free to switch when project required)
- 1x PIR Lens cover (Adjust its detection pattern when various application required)
- 1x A set of screws (Installation required)




BLE to 0-10V Ceiling Mounted AC PIR Sensor With Relay SR-SV9030B-PIR-LBV

Dimension



Wiring



Note: With Max.20mA 0-10V BUS current output, it shall connect Min.10pcs 0-10V Driver.

Warning • DO NOT install with power applied to device.

• DO NOT expose the device to moisture.


Technology Partner SILVAIR Work with Silvair

Bluetooth[°] C € ∠K Ø RoHS ∑

Application



1. Power up the sensor. The load should come on immediately.



3. Enter the room or make some movement and check that the load switches on.

Specification

ENERGY SAVINGS

- Low/High-end trimming
- Daylight harvesting
- Occupancy/Vacancy detection
- Auto and advanced demand response programs
- Time-of-Day dimming schedule
- Energy monitoring

COMFORT & CONVENIENCE

- Advanced occupancy detections
- · Light-level stability

2. Vacate the room or remain very still

and wait for the load to switch off.

· Do not place the SENSOR near heat

sources, fans or in ventilated ceiling voids.
Do not place close to, or positioned such that, any light source points directly into the

 Ensure wires and cables are securely held within the connection terminals.

Disconnect the SENSOR from the circuit

before performing insulation testing of the


PRECAUTIONS

SENSOR.

wiring circuit.

- Configurable dim-and-linger occupancy
- Personalized setting profile
- Work with kinetic switch keypad and dimmer wallstation
- Multi-scenes control







Semi-sphere application: Split the lens cover into Semi-circle type.




BLE to 0-10V Ceiling Mounted AC PIR Sensor With Relay SR-SV9030B-PIR-LBV


Detection

Pattern

Coverage Side View




Coverage Top View



The detection area for movement sensor can be roughly divided into two parts:

Slow movement (person moving < 1.0'/s or 0.3m/s) Quick movement (person moving > 1.3'/s or 0.4m/s)




Default sensitivity: 80% (opm at 3m height)


Detection Area

Note:

1) Following different detection areas are based on different installation heights & patterns.

2) Detection Pattern is a relevant value, the performance should depends on the site conditions (installation height/temperature/sunlight/humidity/Blind area...etc)






Low-bay lens detection pattern at 3m

High-bay lens detection pattern at 3m



Bluetooth C € └└└ ØRoHS X

Place/Detection instruction



Installation Precautions

- · Avoid areas with frequent temperature changes: Keep away from air conditioners, fans, refrigerators, ovens, and other objects that cause rapid temperature changes. The detection effectiveness of PIR motion sensors is closely related to temperature fluctuations, and vents or heat sources can lead to false alarms.
- . Avoid areas with significant air flow.
- Avoid facing glass doors and windows directly: 1) Do not face glass doors and windows directly to avoid interference from strong light. 2) Avoid complex environments outside doors and windows, such as direct sunlight, crowds, and moving vehicles.
- Avoid installing opposite large, constantly moving objects: Large objects with significant motion • can cause sudden changes in airflow within the detection area, leading to false alarms. Outdoor PIR motion sensors should not be installed opposite large trees or tall bushes.
- Avoid areas with screens, furniture, large potted plants, or other obstacles within the detection range.
- · Avoid areas exposed to direct sunlight.

Update Log

Date	Version	Update Content	Update by
2024-11-11	V1.0	Initial Version	Romeo



Subject to change without notice. Please contact us if you have any questions.